



LISTING INFORMATION OF
PyroPhobic - Intulight
SPEC ID: 33660

Pyrophobic Systems Ltd
649 Welham Road
Barrie, ON, ON L4N 0B7
Canada

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

Pyrophobic's Intulight is an ETL Recognized Component, intumescent kit which consists of a puck and collar intended to provide cylindrical lighting assemblies constructed of galvanized steel and their assembly a maintained fire rating. The puck is installed within the cylinder around the bulb interface and the collar on the exterior of the surface of the cylinder above the plate. The Intulight kit is only to be used with approved Intertek certified and ASTM E119 rated steel light fixtures.

Fire Ratings

Standard/Clause	Rating
ASTM E119	1 hour
ASTM E119	2 hour

Attribute	Value
Criteria	ASTM E119 (2016a)
Criteria	ASTM E119 (2018a)
CSI Code	26 50 00 Lighting
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY F - LIGHT KITS
Listing Section	FIXTURES FOR RECESSED INSTALLATION IN FIRE RATED CONSTRUCTION
Listing Section	Intumescent Fireproofing
Spec ID	33660